

Dearborn County Building Department

OFFICE OF THE BUILDING COMMISSIONER
Phone 812-537-8822

CHECKLIST FOR ROUGH-IN INSPECTION

Name _____

Permit No. _____ Date _____

Location _____

Inspector _____

FRAMING

_____ Treated Plate / Anchor Bolts _____

_____ Floor Joist / Spacing / Span _____

_____ Beam Type / Size / Span _____

_____ Corner Bracing _____

_____ Exterior Stud Size & Spacing _____

_____ Lap Double Plates / 24" _____

_____ Rafters / Trusses _____

_____ Lateral Bracing _____

_____ Ply-Clips _____

_____ Fire Stopping _____

_____ Attic Access / 22" x 30" / 30"H _____

_____ Egress Windows 5 / 5.7 / 44" _____

_____ Basement Escape 24" / 30" / 5 sq. ft. _____

_____ Stairs / 8 1/4" R / 36" W / 6'8" H _____

INSULATION

_____ Exterior Walls / R-19 _____

_____ Ceiling / R-38 _____

_____ Vapor Barrier _____

_____ Baffle Vents _____

_____ Roof Ventilation _____

_____ Insulation Board _____

PLUMBING

_____ Number of Fixtures _____

_____ Size of Pipe _____

_____ Distance from Vents _____

_____ Vent thru Roof _____

_____ Supports _____

_____ Clean Outs _____

_____ Hose Bibbs / Antisiphon _____

_____ Pressure-Balance Valve / Shower _____

_____ Waste Test / 5 lbs. _____

_____ Water Test / 50 lbs. _____

_____ Gas Test / 10 lbs. _____

_____ Tempered Glass / 60" H Bottom _____

ELECTRICAL

_____ Service / Amps / Wire Size _____

_____ Sub Feed / 4 Wire Size _____

_____ Grounding / #4 CU. / #2 AL _____

_____ Bonding Metallic Lines / #4 CU. _____

_____ Bonding Whirlpool Motor / #8 CU. _____

_____ Spacing of Boxes / 6'-12' / 2'-4' KC _____

_____ Box Wire Fill / 14-2.0 / 12-2.25 / 10-2.5 _____

_____ 18 Cu. In. / 9-14 / 8-12 / 7-10 _____

_____ Fan Location _____

_____ Protection Plates / 1 1/4" _____

_____ Approved Recess Lite Location _____

BRANCH CIRCUITS

_____ Range / 40A _____

_____ Dryer / 30A _____

_____ Furnace _____

_____ Compressor / 30A _____

_____ H2O Heater / 30A _____

_____ Lighting / 15 A _____

_____ 2 - Small Appliances / 20A _____

_____ Dish Washer / 20A _____

_____ Microwave / 20A _____

_____ Disposal / 15 A _____

_____ Bath GFCI / 20A _____

_____ Smoke Detectors / 15A _____

_____ Washer / 20A _____

HEATING

_____ Duct Supports _____

_____ Tape or Screws / 3 _____

_____ Gas / Shut-Off Valve / Unions _____

FIREPLACE

_____ Clearance _____

_____ Secured to Frame _____

_____ Type of Vent _____

_____ Fire Stop _____

_____ Shut-Off Valve _____

COMMENTS

